



प्रसार भारती / PRASAR BHARATI



भारत का लोक सेवा प्रसारक / India's Public Service Broadcaster

सहायक अभियंता का कार्यालय, सिविल निर्माण स्कंध (विद्युत), दूरदर्शन केन्द्र परिसर, छज्जुबाग पटना- 800 001.

O/o. Asst. Engineer(E), Civil Construction Wing, All India Radio, Doordarshan Complex, Chhajubagh, Patna -800 001.

ई-मेल/ e-Mail : aeecwpat@gmail.com कार्यालय दूरभाष व फैक्स न. / Office Telephone & Fax No.: 0612-2227701



No. 06/AE (E)/PAT/NIQ/2019-20/ 69

Date: 12.02.2020

Notice Inviting Quotation

Sealed Quotations are invited on behalf of President of India on item rate basis from enlisted contractors of CPWD, MES, BSNL, and Bihar State PWD, & Jharkhand State PWD and specialized agency of EFA work. The intending agencies should submit their price bid in sealed envelope so as to reach this office on or before

19 /02/2020 by 03:00 P.M. The quotation shall be opened on same day at 03:30 P.M. in presence of intending bidder or their representative. **The Envelope should be super scribed with name of work.** The undersigned reserves the right to reject any or all the quotations without assigning any reasons.

NAME OF WORK: Providing Early Fire System in News Room and other Ancillary Rooms at, DDK, Ranchi.

Ahram
A
PSM
ARUB

Schedule of work	As per attached schedule sheet
------------------	--------------------------------

Terms and Conditions:-

- Blank Schedule of Quantity shall be issued by AE (E), CCW, AIR, Patna up to 04:00 P.M. on 18 /02/2020 (Blank schedule can be down loaded from bhinternet@air.org.in OR www.tenderwizard.com /AIR)
- Rate of the item should be inclusive of GST and duties etc. nothing will be paid extra on any account.
- Time for completion is 01(one) Month.
- Work is to be done as per relevant CPWD specifications
- No advance payment shall be made.
- Trade license and PAN Card to be submitted.

Assistant Engineer (Elect.)

M/s _____

Copy to:-

- The EE (E), CCW, AIR, Patna for kind information.
- ☒ The Shri D. C. Shukla, Director(Tech.), Prasar Bharati, New Delhi with request to upload this notice on Prasar Bharati website.(Email-bhinternet@air.org.in and akshrivastava@prasarbharti.gov.in)
- Notice Board.
- Spare copies for Agencies

(Agency)
(Signature with Stamp)

Assistant Engineer (Elect.)

Name of Work: -Providing Early Fire Alarm system in News room and other ancillary rooms at DDK Ranchi.						
S.NO	Description of Items	QTY	Unit	Rate	Amount	Remarks
1	Supplying, Installation, testing and commissioning of four zone conventional type fire control panel (UL approved). (Make M/S Agni / Precision / Ravel complete etc as reqd.(One No for News Room & One No for Earth Station)	2	Each			
2	Supplying, Installation, testing and commissioning of smoke detector with dual LED fo 360° view te detector shall be (UL approved). (Make M/S Agni / Precision / Ravel compatible to above control panel complete etc as reqd.(For News Room & Earth Station)	18	Each			
3	Supplying, Installation, testing and commissioning of Response indicator (Make M/S Agni / Precision/Ravel complete etc as reqd.(For News Room & Earth Station)	9	Each			
4	Supplying, Installation, testing and commissioning of conventional type manual call point Break/Re-setable (ABS/Plastic type) (Make M/S Agni / Precision/Ravel complete etc as reqd.(For News Room & Earth Station)	4	Each			
5	Supplling, installation, testing and commissioning of low intensity strobe Hotter suitable for 12V / 24V DC operation as required as per specification (As per M/S Ravel/Prakash Flow Control / FEC / Precision / Kheraj make)(For News Room & Earth Station)	2	Each			
6	Supplying and fixing of following sizes of 2 x 1.5 Sqmm copper conductor armoured cable suitable for fire alarm work and colour code Red on surface/recess etc as required.(For News Room & Earth Station)	250	Mtr.			
				Total Rs	-	
				Assistant Engineer(Elect)		
				CCW,AIR,Patna		

Name of Work: - Providing Early Fire Alarm system in News room and other ancillary rooms at DDK Ranchi.						
S.NO	Description of Items	QTY	Unit	Rate	Amount	Remarks
1	Supplying, Installation, testing and commissioning of four zone conventional type fire control panel (UL approved). (Make M/S Agni / Precision / Ravel complete etc as reqd.(One No for News Room & One No for Earth Station)	2	Each			
2	Supplying, Installation, testing and commissioning of smoke detector with dual LED fo 360° view te detector shall be (UL approved). (Make M/S Agni / Precision / Ravel compatible to above control panel complete etc as reqd.(For News Room & Earth Station)	18	Each			
3	Supplying, Installation, testing and commissioning of Response indicator (Make M/S Agni / Precision/Ravel complete etc as reqd.(For News Room & Earth Station)	9	Each			
4	Supplying, Installation, testing and commissioning of conventional type manual call point Break/Re-setable (ABS/Plastic type) (Make M/S Agni / Precision/Ravel complete etc as reqd.(For News Room & Earth Station)	4	Each			
5	Supplying, installation, testing and commissioning of low intensity strobe Hotter suitable for 12V / 24V DC operation as required as per specification (As per M/S Ravel/Prakash Flow Control / FEC / Precision / Kheraj make)(For News Room & Earth Station)	2	Each			
6	Supplying and fixing of following sizes of 2 x 1.5 Sqmm copper conductor armoured cable suitable for fire alarm work and colour code Red on surface/recess etc as required.(For News Room & Earth Station)	250	Mtr.			
				Total Rs	-	
				Assistant Engineer(Elect)		
				CCW,AIR,Patna		