

 सत्यमेव जयते	PRASAR BHARATI (India's Public Service Broadcaster) DOORDARSHAN KENDRA : R.G. BARUAH ROAD GUWAHATI- 781024 Phone No.0361-2202401/2203407 e-mail-ddgeng.ghy@gmail.com ddgp.ddk@gmail.com	
---	--	---

No.DDK/GUW/Engg stores/2023-24/ 3508

Dated:- 25/10/2023

CORRIGENDUM-1

Ref Enquiry No. :- NIQ-3/DDK/GUW/MW/2023-24/3482 dated 19.10.2023

Refilling and Labeling of Fire Extinguishers.

The following amendment has to be done:-

The hydraulic pressure testing should be carried out for CO2- 4.5 Kg(17 Nos) and CO2- 22.5 Kg (1 No) before refilling and the worn out hose pipe with horn to be replaced if required.


Sealed Cover Should be addressed to
"Deputy Director General(Engg.) and send to---

Assistant Engineer(Engg.Stores)
Doordarshan Kendra, R G Baruah Road,
Guwahati- 781024

Revised Financial Quotations are invited as detailed below.

Sl.No.	Description		Rate per work	
	Type of Fire Extinguisher/Capacity	No of units required to be refilling	Rate of refilling per unit	Total Amount
1	CO2 4.5 Kg	17 Nos		
2	CO2 22.5 Kg	1 No		
3	Dry Powder 5 Kg	49 Nos		
4	ABC Type Dry Powder 5 Kg	2 Nos		
5	ABC Type Dry Powder 4 Kg	1 No		
6	ABC Type Dry Powder 2 Kg	1 No		
7	Foam Type 9 Litres	2 Nos		
8	Water type Gas Pressure 9 Litres	5 Nos		
9	Hydraulic pressure testing CO2- 4.5 Kg	17 Nos		
10	Hydraulic pressure testing CO2- 22.5 Kg	1 No		
11	GST %			

All other terms and conditions of the Tender remains the same.


 (M. Ramanna Naika)
 Assistant Engineer(Store)
 For Dy. Director General(E)

25/10/2023